



- ADDITIONAL SPECIAL NOTES:**
1. Contractor must supply approved Engineers plans and design certificate.
  2. 18m x 12m x 3.6m Portal frame structure.  
(The Portal frame structure must have a minimum height of 3.6m)
  - Painting of the Portal frame structure: One (1) coat of grey etch primer and two (2) coats of QD enamel to the columns, rafters and bracings.
  3. 0.5mm IBR cladding - Z150 Galvanized coating
  4. 2 x 2m sliding doors, to open to both sides, on gable ends, according to the Engineers designs.
  5. 2 x 1.5m sliding doors according to the Engineers designs, as indicated on floor plan.
  6. 140 x 190 x 390mm concrete blocks built up to 900mm above floor level.
  7. IBR to overlap block wall by atleast 500mm.
  8. 8 x Translucent sheets (0.5mm) to be fitted on the roof, 4 on each side.
  9. 150mm by 100mm Galvanized steel gutters with 76mm downpipes

NO.	SPECIAL NOTES:
1.	150mm Reinforced Concrete floor: 25Mpa with a steel float finish
2.	500 Micron DPC under reinforced floor.
3.	150mm Ramps on 4m entries.
4.	100mm Ramps at 1.5m entries.
5.	1000x100mm Apron around the structure

**RURAL DEVELOPMENT AND AGRARIAN REFORM**  
**PROVINCE OF THE EASTERN CAPE**  
  
 ENGINEERING SERVICES  
 Private Bag X015  
 DÖHNE ADI  
 STUTTERHEIM  
 4930

<b>MULTIPURPOSE SHED</b>	SCALE NOT TO SCALE	INDEX NO.: SCNM0013304
<b>ELEVATIONS</b>	A3 ORIGINAL	PLAN NO.: SHEET 4 OF 4